


Note: All Joints Shall Be Restrained Except In Run Of Tee.

PLAN



SECTION

Notes:

- 1) Megalug flanges shall be used for all mechanical joints.
- 2) Bell end pieces of pipe 4 ft. and smaller shall be considered scrap, and shall not be installed into system.

| | | | |
|------------------------------------|---------------------|---|-------------------|
| CITY OF CARMEL STANDARD DETAILS | | TITLE: WATER MAIN CONNECTION DETAIL | |
| Date: March 2001 | Scale: Not To Scale | Drawn By: Jones & Henry Engineers, Inc. | Drawing Name: CW5 |