



Notes:

1. At High Points Along Main Water Line Where Indicated On Drawings, Anchoring Tee Shall Be Set At 45° Angle Upwards And Connected To 6" 45° Bend. Main Water Line Shall Be Lowered To Provide Sufficient Cover As Specified.
2. All Joints Shall Be Restrained Except In Run Of Tee.
3. Hydrants Shall Be Set At 500' Max. Horizontal Distance, Or Less As Specified By Fire Department
4. All valves must include Posi-Cap or equivalent
5. Hydrant Valves must be restrained to the tee with either all thread, or an anchoring tee.
6. All Hydrant Stubs must have tracer wire

CITY OF CARMEL STANDARD DETAILS		TITLE: FIRE HYDRANT ASSEMBLY	
		Date: <i>March 01</i>	Scale: Not To Scale