

PRESSURE PIPE JOINT RESTRAINT TABLE										
<i>Length Of Pipe To Be Restrained in Each Direction From ? Of Bend Based On 150 PSI Test Pressure</i>										
<i>Degree Of Bend</i>	<i>6"</i>	<i>8"</i>	<i>10"</i>	<i>12"</i>	<i>14"</i>	<i>16"</i>	<i>18"</i>	<i>20"</i>	<i>24"</i>	<i>30"</i>
<i>90°, Tees & Plugs</i>	<i>27'</i>	<i>35'</i>	<i>42'</i>	<i>50'</i>	<i>58'</i>	<i>65'</i>	<i>73'</i>	<i>80'</i>	<i>95'</i>	<i>115'</i>
<i>45°</i>	<i>7'</i>	<i>9'</i>	<i>11'</i>	<i>13'</i>	<i>15'</i>	<i>17'</i>	<i>19'</i>	<i>21'</i>	<i>24'</i>	<i>29'</i>
<i>22-1/2°</i>	<i>3'</i>	<i>4'</i>	<i>5'</i>	<i>6'</i>	<i>7'</i>	<i>8'</i>	<i>9'</i>	<i>10'</i>	<i>12'</i>	<i>14'</i>
<i>11-1/4°</i>	<i>2'</i>	<i>2'</i>	<i>3'</i>	<i>3'</i>	<i>4'</i>	<i>4'</i>	<i>4'</i>	<i>5'</i>	<i>6'</i>	<i>7'</i>

*Restrained Joints Shall Be Mechanical Joint With Retainer Glands,
US Pipe TR Flex Joint System, US Pipe Field LOK Gasket System,
Or Equal.*

*NOTE: THE ABOVE RESTRAINED JOINT LENGTHS ARE MINIMUM LENGTHS
THE DESIGN ENGINEER SHALL DETERMINE IF LONGER LENGTHS ARE REQUIRED.*

CITY OF CARMEL STANDARD DETAILS		TITLE: JOINT RESTRAINT TABLE	
Date: March 2001	Scale: Not To Scale	Drawn By: Jones & Henry Engineers, Inc.	Drawing Name: CW10