



NOTES:

1. CONCRETE SHALL BE HIGH-EARLY YIELD AND SHALL NOT BE BACKFILLED UNTIL ENGINEER DEEMS THE CONCRETE ADEQUATELY CURED.
2. TO BE USED WHEN COVER OVER TOP OF PIPE IS LESS THAN 4 FEET, PER ENGINEER'S DIRECTION OR WHERE NOTED ON THE CONSTRUCTION PLANS.

City of Carmel Utilities
Standard Details

Title:

CONCRETE
ENCASEMENT DETAIL

Date: January 2016

Scale: Not To Scale

Drawing: CS 33

Page 36