



NOTE:

- 1) 1" Or Smaller Service Line Shall Be Direct Tap Unless Approved By Carmel Utilities.
- 2) Corporation Stop Shall Be Brand And Model Approved By Carmel Utilities.
- 3) Service Line Tap Shall Be Installed With A Min. Horiz. Separation of 24".
- 4) 2 Inch Taps And Smaller Shall Not Be Installed Within 18 Inches of Mechanical Joints And Bells.

* Service Saddle Must Be Omitted For Services 1" And Smaller And Direct Taps Made to Ductile Iron Pipe, Class 350 Or Greater. (Verify With Owner For Pressure Class DIP.)

** For all Service Lines Installed Under Pavement Install HDPE Sleeve Under Pavement Section.

CITY OF CARMEL STANDARD DETAILS		TITLE: RESIDENTIAL WATER SERVICE (NO CURB STOP) DETAIL	
<u>DATE:</u> MARCH 2007	<u>SCALE:</u> NOT TO SCALE	<u>DRAWN BY:</u> CROSSROAD ENGINEERS, PC	<u>DRAWING NAME:</u> CW4-3